

CERTIFICATE


of Conformity

Registration No.: AK 50636276 0001
Report No.: CN244I1Y 001
Product: Circulation Pump (Circulation Pump)

Type designation listed on the next page

The certificate of conformity refers to the above-mentioned product. This is to certify that the specimen is in conformity with the assessment requirement mentioned on the next page. This certificate does not imply assessment of the production of the product and does not permit the use of a TÜV Rheinland mark of conformity.

Certification Body



Min Xu

Date: 2024-07-04



TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

CERTIFICATE

of Conformity

Registration No.: AK 50636276 0001

Product: Circulation Pump
(*Circulation Pump*)

Tested according to: EN 16297-1:2012
EN 16297-2:2012

Identification: Type Designation
SBT32-6 III; Master 32-6 III
Series No.: Engineering Sample
Compliance with Commission Regulation
(EU) No 622/2012 amending Regulation
(EC) No 641/2009 -implementing Directive
2005/32/EC (2009/125/EC, recast) of the European
Parliament and of the Council with regard
to ecodesign requirements for glandless
standalone circulators and glandless circulators
integrated in products
-Annex I and Annex II
EEI≤0.20



TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg