


回路示意图
Distribution



- TECHNICAL REQUIREMENTS:
1. FPI=23,
 2. TUBE=16*1.3*16,
 3. INLET AND OUTLET PIPES ARE COPPER TUBES;
 4. COIL INTERNAL VOLUME:0.174L;
 5. MAX OPERATING PRESSURE:4.5 MPA;
 6. BURST PRESSURE:13.5MPA.

图纸客户确认栏
Customer Approve

签字 _____

Sign _____

未注线性尺寸公差/Unmarked Linear Tolerance	微通道冷凝器/Condenser	1st Angle 一角法	
≤6 ±0.3 >6~30 ±1 >30~120 ±1.5 >120~400 ±2 >400~1000 ±3 >1000~2000 ±4 >2000 ±5		比例/ Scale	1: 3
未注角度公差/Unmarked Angle Tolerance		版本/ Rev.	00
直角/Right angle ±2° 其它角/Other Angle ±3°		页码/ Page	第 1 页 共 1 页 Page 1 Total 1
设计/DRN Bing Guan 校对/CHK 审核/ENG 工艺/MFG	标准/Standardize	批准/APR 日期/Date	X001-SD10-5 SMH PN:101005450
		Sanhua (HangZhou) Micro Channel Heat Exchanger Co., LTD	