


- TECHNICAL REQUIREMENTS:**
1. FPI=23,
  2. TUBE: 16\*1.3\*16,
  3. INLET AND OUTLET PIPES ARE COPPER TUBES;
  4. COIL INTERNAL VOLUME:0.400L;
  5. MAX OPERATING PRESSURE:4.5 MPA;
  6. BURST PRESSURE:13.5MPA.



图纸客户确认栏  
Customer Approve

签字 \_\_\_\_\_  
Sign \_\_\_\_\_

|                                    |                        |  |                               |      |
|------------------------------------|------------------------|--|-------------------------------|------|
| 未注线性尺寸公差/Unmarked Linear Tolerance |                        | 微通道冷凝器/Condenser   | 1st Angle<br>一角法              |      |
| ≤6<br>±0.3                         | >6~30<br>±1            |  | 比例/<br>Scale                  | 1: 3 |
| 未注角度公差/Unmarked Angle Tolerance    |                        | Sanhua (HangZhou) Micro<br>Channel Heat Exchanger Co., LTD | 版本/<br>Rev.                   |      |
| 直角/Right angle<br>±2°              | 其它角/Other Angle<br>±3° |  | 00                            |      |
| 设计/DRN<br>Bing Guan                | 标准/Standardize         | 页码/<br>Page  | 第 1 页 共 1 页<br>Page 1 Total 1 |      |
| 校对/CHK                             | 批准/APR                 | X001-SD13-5  |                               |      |
| 工艺/MFG                             | 日期/Date                | 101005490  |                               |      |